



CERTIFICATION RECORD

The company named below has been authorized by CSA International to represent the products listed in this record as "CSA Certified" and to affix the CSA Mark to these products according to the terms and conditions of the CSA Service Agreement and applicable CSA program requirements (including additional Markings).

File No: 263332 Alternate File: 263332

Class No: 8029 17 BUILDING PRODUCTS AND MATERIALS - Side-hinged Doors (Harmonized Standard)

LISTEE

4877312 Procanna
5A-225 Henry Street
Brantford, ON N3S 7R4
Canada

SUBMITTOR

4642495 Atlantic All Weather Windows Ltd.
49 East Main St
Port Elgin, NB E4M 2X9
Canada

April 1, 2015

• PVC Side-Hinged Doors certified to AAMA/WDMA/CSA 101/I.S.2/A440-08 & A440S1-09:

Model/Type	Primary Product Designator	Positive Design Pressure Pa (psf)	Negative Design Pressure Pa (psf)	Water Resistance Test Pressure Pa (psf)	Canadian Air Infiltration/Exfiltration
Bermuda Series Outswing Single Door ¹ , 2 3/4" Flush Frame	Class R-PG65-SHD Size tested 1221 x 2439 mm (48 x 96 in)	3120 (65.0)	-3120 (-65.0)	730 (15.0)	A3 Level
Bermuda Series Outswing Single Door ² , 2 3/4" Flush Frame	Class R-PG65-SHD Size tested 1221 x 2439 mm (48 x 96 in)	3840 (80.0)	-3840 (-80.0)	730 (15.0)	A3 Level
Bermuda Series Outswing Double Door ³ , 2 3/4" Flush Frame	Class R-PG65-SHD Size tested 2086 x 2186 mm (82 x 86in)	3120 (65.0)	-3120 (-65.0)	730 (15.0)	A3 Level

• PVC Fixed Door certified to AAMA/ WDMA/ CSA 101/ I.S.2/ A440-08 & A440S1-09:

Model/Type	Primary Product Designator	Positive Design Pressure Pa (psf)	Negative Design Pressure Pa (psf)	Water Resistance Test Pressure Pa (psf)	Canadian Air Infiltration/Exfiltration
Bermuda Fixed Door with Transom and Sidelite, FS-FXD-FXD	Class LC-PG50-FD Size tested 2438 x 2743 mm (96 x 108 in)	2400 (50.0)	-2400 (-50.0)	730 (15.0)	Fixed Level

• Side-Hinged Doors certified to AAMA/ WDMA/ CSA 101/ I.S.2/ A440-08 & A440S1-09:

Type/Model	Primary Product Designator	Positive Design Pressure Pa (psf)	Negative Design Pressure Pa (psf)	Water Resistance Test Pressure Pa (psf)	Canadian Air Infiltration/Exfiltration
Outswing Garden Door with Transom and Brick Mould, PIC/ OS-FXD ⁴	Class R-PG25-SHD Size tested 1875 x 2828 mm (74 x 111)-LW	1200 (25.0)	-1200 (-25.0)	0 (0.0)	A3 Level
Outswing Venting Terrace Steel Door with Transom and Brick Mould, VTD-PIC/ OS-VTD ⁷	Class R-PG25-SHD Size tested 1902 x 2828 mm (75 x 111)-LW	1200 (25.0)	-1200 (-25.0)	0 (0.0)	A3 Level
Inswing Garden Door with Transom and Brick Mould, PIC/ IS-FXD ⁴	Class R-PG25-SHD Size tested 1873 x 2854 mm (74 x 112)-LW	1200 (25.0)	-1200 (-25.0)	0 (0.0)	A3 Level
Inswing Steel Door with Transom, Sidelites and Brick Mould, Pic/ Sidelite-LHIS-Sidelite ⁵	Class R-PG25-SHD Size tested 1720 x 2828 mm (68 x 112)-LW	1200 (25.0)	-1200 (-25.0)	0 (0.0)	A3 Level
Outswing Steel Door with Transom, Sidelites and Brick Mould, Pic/ Sidelite-LHOS-Sidelite ⁵	Class R-PG25-SHD Size tested 1722 x 2828 mm (68 x 111)-LW	1200 (25.0)	-1200 (-25.0)	0 (0.0)	A3 Level
Outswing Double Steel Door with Brick Mould ⁸	Class R-PG20-SHD Size tested 1882 x 2064 mm (74 x 81)	960 (20.0)	-960 (-20.0)	180 (3.75)	A3 Level

Outswing Double Steel Door (Reinforced) with Brick Mould ⁸	Class R-PG25-SHD Size tested 1882 x 2064 mm (74 x 81)	1200 (25.0)	-1200 (- 180 (3.75) 25.0)	A3 Level
In-swing High Performance Steel Door/ Double Sidelite, Side-Hinged Door with Transom ⁶	Class R-PG20-SHD Size tested 1727 x 2883 mm (68 x 114)	960 (20.0)	-960 (- 260 (5.25) 20.0)	A3 Level
Outswing Single Steel Door LH with Brick Mould (Full Lite) ⁹	Class R-PG30-SHD Size tested 944 x 2075 mm (37 x 82)	1440 (30.0)	-1440 (- 360 (7.50) 30.0)	A3 Level
Outswing Single Steel Door LH with Brick Mould (Solid Panel) ⁹	Class R-PG35-SHD Size tested 944 x 2075 mm (37 x 82)	1680 (35.0)	-1680 (- 360 (7.50) 35.0)	A3 Level

DP= Design Pressure

¹Type E of AAMA/WDMA/CSA 101/I.S.2/A440-08

- Number of panels: (1) outward-opening
- Using multipoint hardware without Top Shoot bolt and Shoot bolt Striker plates

²Type D of AAMA/WDMA/CSA 101/I.S.2/A440-08

- Number of panels: (1) outward-opening
- Using multipoint hardware with Top Shoot bolt and Shoot bolt Striker plates

³Type D of AAMA/WDMA/CSA 101/I.S.2/A440-08

- Number of panels: (2) outward-opening

⁴Type C of AAMA/WDMA/CSA 101/I.S.2/A440-08 with a transom

- Number of panels: (1) active door panel, (1) passive door panel and (1) transom

⁵Type E of AAMA/WDMA/CSA 101/I.S.2/A440-08 with a transom

- Number of panels: (1) active door panel, (2) side lites and (1) transom

⁶Side-Hinged Door, Type E of AAMA/WDMA/CSA 101/I.S.2/A440-08 with a transom

- Number of panels: (1) inward-opening and (2) fixed panels

⁷Side-Hinged Door, Type D of AAMA/WDMA/CSA 101/I.S.2/A440-08 with a transom

- Number of panels: (2) active door panels and (1) transom

⁸Side-Hinged Door, Type D of AAMA/WDMA/CSA 101/I.S.2/A440-08

- Number of panels: (2) active door panels

⁹Side-Hinged Door, Type B of AAMA/WDMA/CSA 101/I.S.2/A440-08

- Number of panels: (1) active door panel

/lb